


ITEM	DESCRIPTION
1	HV CABLE BOX 3 POLE 1 GLAND (TERMINATION KIT REQD)
2	LV CABLE BOX 4 POLE 7 GLAND AIR FILED
3	TRANSFORMER LIQUID FILLER PLUG
4	THERMOMETER POCKET
5	LIQUID LEVEL GAUGE
6	JACKING ANGLES
7	EARTHING TERMINAL
8	SKID UNDERBASE C/W HAULAGE HOLES
9	MAIN LIFTERS
10	BREATHER PIPE C/W BREATHER (SUPPLIED LOOSE)
11	TAPPING SELECTOR CONTROL HANDLE
12	RATING AND DIAGRAM PLATE
13	DRAIN VALVE
14	RADIATORS

BOWMERS JCT. No.	BOWMERS STOCK No.
1000	1000
433	433
1333	1333
3	3
50Hz	50Hz
Dyn11	Dyn11

ESTIMATED WEIGHTS	KG
CORE AND WINDINGS	1455
COOLING LIQUID - 705 LTRS	603
TOTAL WEIGHT	3040



**BM TRADA**  
CERTIFICATION

**UKAS**  
MANUFACTURE

ISO 9001 : 2008

This drawing is COPYRIGHT and the property of Bowers Electricals Ltd. It must not be copied (in whole or in part) without prior written consent of the company.

**TOLERANCE UNLESS OTHERWISE STATED**  
 ± 0.5mm FOR DIMENSIONS UP TO 250mm;  
 ± 1.0mm FOR DIMENSIONS UP TO 1000mm;  
 ± 2.0mm FOR DIMENSIONS OVER 1000mm.

1

BREATHER, DRAIN VALVE AND PHASE LABELS UNPAINTED

Date: 11/10/11

Signed: AMV

Ckd: CM

**Bowers**  
Electricals Ltd

Heaton Gate Road, DRYBURY, STAFFS, ST16 1JH  
Tel: 01773 531531 Fax: 01773 716171  
Email: enquiries@bowerselec.co.uk

Drawn by: CM/ESSE

Checked by: D/RESB/IT

Approved by: AS

Original No: 7160697\_38

Date: 09/09/11

Dwg. Size: A2

GENERAL ARRANGEMENT OF 1000KVA ONAN STD TRANSFORMER BSEN60076

DRG No. BE5321

Scale: 1:20

Revison: 1/1

Sheet: 1/1